



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	06-17-02	Interpretation #	02-025
Topic	Changes in Level in Corridors and Hallways R-2 Occupancies		
Code Section(s)	§1007.6.3.4, California Building Code (1998)		
Requested by	Bryan Wadlington San Miguel Fire Protection District 2850 Via Orange Way Spring Valley, CA 91978-5331		

Since all required exits in Group R, Division 2 occupancies must go to a public way, is it the intent of the State Fire Marshal that Section 1007.6.3.4 of the California Building Code (1998) be used for the entire path of travel to the public way or is this section only intended to apply to the interior hallways and corridors?

Section 1007.6.3.4 applies specifically to the interior exiting system.